

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 100

Dated: 4-4-2026

It is certified that an inspection team headed by Dr. K. Srinivasulu

(Name of Officers with designation) from Medical Officer PHED

inspected the RSR English Medium High School, Gowravaram, Kavalim

(Name & Address of the school) on 3-4-2026 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 117 dated 4-4-2026

of Division Level Water Testing Laboratory (PHED Lab) certified that

the RSR English Medium High School (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 4-4-2027

Signature with Seal: Dr. K. Srinivasulu

Name: Dr. K. Srinivasulu

Designation: Medical Officer

Name & Address of the Office / Department: PHC THUMMALAPENTH, Kavalim, SPSR Nellore

To RSR English Medium High School,
Gowravaram, Kavalim, SPSR Nellore
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

Government of Andhra Pradesh IWQM Water Testing Laboratory

The executive Engineer

Rural Water Supply & Sanitation Department

TEST REPORT ON CHEMICAL ANALYSIS OF WATER (DRINKING)

General Physical Chemical Parameters

Bare of Address: RSR English Medium High School, Gowravaram, Kavali Md., SPSR Nellore District.

Test Report ID No: 117

Description of the test items: Chemical Analysis

Date of Collection: 04.04.2026

Data for Analysis: 04.04.2026

Date of Receipt: 04.04.2026

Date of issue: 04.04.2026

Sl. No	Physcio - Chemical parameters	Units	Bore water before filtration	RO Treated water	VMC tap water	Water at Delivery Point	As per IS: (10500 – 2012)	
							Requirement Acceptable Limit)	permissible Limit(in the absence of alternative source)
1	Colour	Co-Pt						
2	Turbidity	NTU	3.00	2.00			1.0	5.0
3	pH		6.90	5.30			6.5-8.5	No relaxation
4	Electrical Conductivity(Ec)	micromhos/cm	886	118			-	-
5	Total Dissolved Solids(TDS)	mg/lit	571	76			500	2000
6	Total Alkalinity as CaCO ₃	mg/lit	432	88			200	600
7	Total Hardness as CaCO ₃	mg/lit	240	32			200	600
8	Calcium as Ca ⁺⁺	mg/lit	80	24			75	200
9	Magnesium as Mg ⁺⁺	mg/lit	38.88	1.94			30	100
10	Flouride as F	mg/lit	1.55	0.30			1.0	1.5
11	Chloride as Cr	mg/lit	120	36			250	1000
12	Nitrate as NO ₃	mg/lit	30.00	25.00			45	No relaxation
13	Total Iron as Fe	mg/lit	0.10	0.00			0.3	1

S. Firozote Bayha
Asst. Executive Engineer
RWS & S Department
Kavali, SPSR Nellore Dist.

K. Ramkishan
Asst. Chemist
Division Level Water Testing Laboratory
Rural Water Supply & Sanitation Dept.
Kavali, SPSR Nellore Dist.



HEALTH & SANITARY CERTIFICATE

Ref: 100

Date: 24-4-2026


This is to certify that the Management of "RSR English Medium High School" has provided sufficient toilets and drinking water provisions to nearly 900 students and 50 staff members.

Separate Toilets for students – 60

Separate Toilets for staff - 10

Drinking water – R.O. water system

All the toilets are well maintained and sanitary conditions are satisfactory. Drinking water system is well maintained and in hygienic condition.


MEDICAL OFFICER
PHC THUMMALAPENTA
Kavali (M.), SPSS Kavali (M)

Primary Health Centre
Thummalapenta, Kavali(M)